



# Cobb Generation and Storage

Takaka 2015





**Kirsty Joynt**

Lead Environmental Advisor,

Environmental Group, Generation.

**Peter Lilley**

Strategy & Development

Portfolio Team, Generation.

# Contents



Consents

Catchment

Storage

Operation

Other notes

Discussion

# Consents

## Key Dates

- Granted 2003
- 35 year consent term
- 5 yearly review provision

## Operating Parameters

- Lake level limits
- Max take from Cobb Reservoir 10 cumecs
- Max discharge from station 10 cumecs
- Currently discharge capability 7.5 cumecs

## Monitoring

- Water quality
- Aquatic macro invertebrates
- Native fish and trout

## Tasman Environmental Trust

- Trust administers the Cobb Mitigation Fund
- Total \$600k in three instalments of \$200k
- Funding for environmental enhancement projects in Golden Bay

# Catchment Characteristics


	Area	Mean Flow		Average Annual Min
	sq km	m <sup>3</sup> /s	Mil m <sup>3</sup>	m <sup>3</sup> /s
Cobb @ Trilobite	47.0	3.80	120	0.37
Cobb Reservoir (surface area)	2.1			
Cobb @ Dam (incl lake)	70.0	5.40	170	
Diamond Lakes + Tribs Below Dam	40.0	2.60	82	0.32
Upper Takaka Above Power Stn	100.0	5.00	158	0.70
Lower Takaka Gorge & Tribs	49.0	1.70	54	0.30
Takaka @ Harwoods	260.0	14.70	464	1.33
Takaka @ Kotinga	713.0			
Takaka @ Mouth	890.0			

# Storage Statistics


Level	Level (m)	Operational Storage		Storage / m	
		(mil m <sup>3</sup> )	(GWh)	(mil m <sup>3</sup> )	(GWh)
Max Flood WL	810.1	31.7	42.8		
Top Gates	808.3	27.2	36.7		
Normal Max	807.7	25.8	34.8	2.4	3.3
Spillway Sill	802.5	13.9	18.7	2.3	3.1
Nominal Min	794.0	-	-	1.6	2.2
Extreme Min	792.5				

# Operational Statistics


Portion of Time Output Falls within;



Stations Influence on Flow




# Operational Statistics: All flows





# Operational Statistics: Flow < Median



# Other Notes

## Grid Support

- Station is used for grid support for the area – sometimes “Must Run”

## Location Value

- Partially offsets the higher cost of power paid by Top of Sth Is due to transmission.

## High Head

- Highest Station Head in NZ = most efficient converter of flow to energy.

## Moderate Storage

- Storage is moderate in terms of % of annual flow volume (18%)

## Good Utilisation

- Storage utilisation is good – 230% (refills on average every 5 ½ months).

## Low-Moderate Spill

- Spill frequency – low-moderate. (nil to several times per annum).

