

Appendix 3

RESC11-06-04 – Utilities - Water Supply Exceptions

Date	Location	What	Why	Remedial Action
30/03/2011	Mapua – Aranui Road (outside 4 Square Supermarket)	200mm dia PVC main break	Fragile pipe	Repaired with 6m section of new pipe.
08/04/2011	Dovedale – Supplejack Valley Road	65mm dia PVC main break	Fragile pipe	Repaired with 1m section of new pipe.
24/04/2011	Richmond – Appleby Highway at 3 Brothers Corner	150mm dia AC main break	Roadworks disturbance. Close to fragile pipe	Repaired with section of new pipe.