

Appendix 1

RESC11-06-04 – Utilities – Wastewater Treatment Plants - Compliance with Consent Conditions

WWTP	Compliance	If “no”, What	Why	Remedial Action
Collingwood	Yes			.
Motueka	No	Overflows from the northern end of wetland adjacent to river/estuary	High rainfall, and high inflow into WWTP	Warning Signs alerting public to potential overflows. TDC compliance notified. Planned upgrade to include alternative disposal method
Murchison	Yes			
St Arnaud	Yes			
Takaka	No	TSS recorded above consent limit in three wetland cells on 21 March 2011. BOD <sub>5</sub> above consent limit in two marsh cells	Lack of vegetation in cells contributes to poor TSS removal	Retest undertaken, results yet to come TDC Compliance notified
Tapawera	Yes			
Upper Takaka	No	Flows above consent limit to WWTP. Flows range 43-67m <sup>3</sup> /day between 23-25 April	High Rainfall, high groundwater causing infiltration into private laterals	TDC Compliance notified. Staff to approach GB Community Board regarding private lateral issues.