

Appendix 2 – RESC11-08-08 – Utilities

Wastewater Exceptions

Location	Date	What	Why	Remedial Action
78 Tudor Street, Motueka	05/05/11	Sewage backed up onto property from council sewer pipes.	Collapsed lateral.	Downer to investigate.
Thorp Street, Motueka	09/05/11	Toilet area blown out.	Truck that was clearing out the lines.	Water blaster was sent up the lines and mess was cleaned up.
Sanderlane Drive Sewer PS, Motueka	16/05/11	Pump 2 seized.		Taken to Motor Rewinds for an overhaul.
239 Thorp Street, Motueka	24/05/11	Wastewater is backing up from pump station.	Pump had been blocked and would not run properly.	Removed pump and cleaned out blockage. Unsure of volume.
Motueka Ponds	10/06/11	Ponds were close to overflowing.	Heavy rain.	Pump was brought in and flow was pumped into marshland.
Thorp Street, Motueka	20/06/11	Red light flashing on pump station.	High level flows.	
477 High Street, Motueka	20/06/11	Water has come right up to toilet bowl.	Goodman Park and Woodlands Avenue PS at high level not keeping up with inflow.	Sepclean removed in excess of 40,000 litres.
Four Winds (Takaka)	02/05/11	Rising main leak for sewer, small trickle.		Cut gibaults into 1m line to repair. Cannot identify volume of overflow.
65 Rototai Road, Takaka	03/05/11	Sewage pump red light is flashing.	Blockage in Pump 2.	Cleared blockage, no overflow.
77 Meihana Street, Takaka	12/05/11	CCTV camera stuck in a Cleaning eye.		Plumber was called and camera was removed.
14 Tata Heights, Takaka	16/06/11	Sewage blockage.	Blockage in lateral.	Dye tested to see if line was blocked. It was cleaned out and unblocked.
Rototai Road, Takaka	26/05/11	Alarm flashing at pump station. Sent second pump into overload.	Loose wire in the main switch.	Downer investigated. Further investigation may be required.
Waimea West Road, Brightwater	05/06/11	Sewerage smells.	Ongoing investigation.	Cleared pipe with 8000l water.
Sommerville Lane, Brightwater	06/05/11	Strong sewerage smell.	Pump was running through the day when it usually runs at night.	Howard turned pump off.
11 Rotoiti Street, St Arnaud	11/05/11	Sewer main blocked.	Hedgehog stuck in the pipe.	Pipe cleared, no sewer overflow.
Beach Road, Richmond	26/05/11	Sewer overflow.	Discharge was due to sewer backed up, no blockage.	Sepclean attended and cleanup was completed.
Eves Valley	31/05/11	High Level.	Due to heavy rain.	

Bell Island	13/06/11	Gate has jammed and will not go up or down.	When it was in use it jammed.	Gate removed for repair.
Bullivant Drive West, Rabbit Island	24/06/11	Possible sewer pipe break.	400 mm sinkhole	Hole reinstated no break.

Sewer Blockages/Overflows

Location	Job Number	Date	What	Why	Remedial Action
78 Tudor Street Motueka	42246	05/05/11	Issue found with lateral.		Repaired, no overflow.
230 Thorp Street, Motueka	42290	09/05/11	Toilet blown.	By CCTV contractor using line.	Customer cleaned up themselves, no further work required.
636 Abel Tasman Drive, Pohara	42201	02/05/11	Wet patch noticed.	PVC in Rising main failed.	Only a trickle, replaced PVC.
Takaka	42078	20/04/11	Strong sewerage smell, toilet not flushing water away.	Blocked manhole because of fat.	Cleared, no overflow.
Gladstone Road, Richmond	42145	27/04/11	Blockage in manhole.		Cleared by Ian, no overflow.
90 Beach Road, Richmond	43363	27/05/11	Sewerage pushing out manholes.	Due to high flows on side of road.	There were 3.5 hours of leakage, volume unknown. Sepclean was used to tidy up.
Gladstone Road, Richmond	42270	06/05/11	System backing up.	High flows.	No overflow.