

Appendix 2 – RESC11-04-05 – Utilities Report

**Wastewater Exceptions**

Date	Location	Why	Remedial Works
05/01/2011	Murchison WWTP	Aerator No.4 removed. Top motor bearing seized.	Repair
05/01/2011	Murchison RRC	Leachate pump removed due to faulty seal.	Repair
02/03/2011	Murchison – Waller Street SPS	Odour complaint in relation to sewer pump station.	New lids being made which should seal wet well better.
28/01/2011	Pohara, Golden Bay	Power failure at Tarakohe sewer pumpstation.	Generator used while power out.
15/02/2011	Mapua – Mapua Wharf SPS	Customer called in regarding odour from pumpstation. Appears to be a recurring problem on still days.	Further investigation required.
02/03/2011	Motueka – Trewavas Street SPS	Faulty pressure transducer	Replaced

**Sewer Blockages/Overflows**

Date	Job Number	Location	Why	Remedial Works
11/01/2011	40499	Takaka; 21 Burnside Road	Blocked gravity line.	Blockage cleared, no overflow occurred.
28/01/2011	40834	Takaka; 41 Commercial Street	Approximately 1m <sup>3</sup> of grey water from caravan discharged into storm gutter.	Sump cleaned out with sucker truck.
14/01/2011	40574	Pohara; Four Winds SPS	Rising main near Selwyn Street found to be leaking. Approximately 1m <sup>3</sup> of wastewater overflowed.	Cleaned up and disinfected.
15/01/2011	40614	Pohara; Four Winds SPS	Rising main- weep found coming out of ground. Approximately 1m <sup>3</sup> of wastewater overflowed.	Cleaned up and disinfected.
11/02/2011	41040	Pohara / Clifton; Boyle Street SPS	Blockage in pump resulted in minor overflow (ground wet around pumpstation).	Pump unblocked.
06/03/2011	41436	Pohara; 670 Abel Tasman Drive	Pipe break in rising main resulted in overflow of approximately 1m <sup>3</sup> of wastewater.	Break repaired, clean up and disinfection undertaken.
08/03/2011	41467	Collingwood; caravan dump site	Pipework blocked resulting in full chamber. No overflow occurred.	Pipework unblocked.
14/01/2011	40579	Motueka Beach Park	Tree roots caused block in main. No overflow occurred.	Blockage cleared.
03/02/2011	40916	Motueka; 39 Trewavas Street	Blocked rising main resulted in overflow of approximately 3m.	Cleaned up and disinfected.
15/02/2011	41137	Richmond; 42 Croucher Street	Blockage in pipework resulted in wastewater backing up through customer gully trap. Approximately 1m <sup>3</sup> of wastewater overflowed.	Cleaned up and disinfected.
26/02/2011	41332	Richmond; Gladstone Road	Motor home pumpstation.	Blockage cleared with sucker truck. No overflow occurred.