

Specified System Form - Page 1

To be completed by applicant/agent with full details when any building consent application incorporates a specified system as detailed in Schedule 1 of the *Building (Specified Systems, Change the Use, and Earthquake-prone Buildings) Regulations 2005*.

Please complete for each individual system incorporated into the building.

Do not leave blank spaces, if information is not yet available please enter *to be confirmed* (TBC). This information will need to be supplied when available, and prior to issue of Code Compliance Certificate (CCC).

Building name or street address	150 Hope Avenue
---------------------------------	-----------------

Specified system	SS4 Emergency lighting systems incl (illuminated exit signs)					
	Existing <input type="checkbox"/>	New <input checked="" type="checkbox"/>	Altered <input type="checkbox"/>	Removed <input type="checkbox"/>		
Description (incl type) <i>Describe the specific type of system which will be provided on the compliance schedule.</i>	Recessed LED and illuminated exit signage.					
Make - Manufacturer name if known	Spitfire	Model name – if known		N/A		
Location	Throughout ground floor tenancy as shown on the Fire Safety Report, version 3 issued by C Docs Ltd dated 14 October 2022.					
Performance standard	AS 2293.1:2005 Emergency escape lighting and exit signs for buildings. Part 1 : System design, installation and operation.					
Inspection requirements	AS/NZS 2293.2.1995					
Inspection frequency	Daily <input type="checkbox"/>	Weekly <input type="checkbox"/>	Monthly <input type="checkbox"/>	3 Months <input type="checkbox"/>	6 Months <input checked="" type="checkbox"/>	Annually <input checked="" type="checkbox"/>
Inspection personnel	IQP for both 6 monthly and annual					
Maintenance requirements	Planned preventative maintenance and responsive maintenance will be carried out in accordance with AS/NZS 2293.2:1995					
Reporting	<p>A test report shall be completed, and results entered into the owner's logbook for inspections specified above.</p> <p>Annually, a test report shall be completed which records the results of all tests and inspections together with a list of non-complying features and corrective measures necessary to return the system to comply with its original install.</p> <p>Annually, a Form 12A is to be filled out. Original to stay with this document and copied to the Tasman District Council.</p>					

Please save this document as a PDF and combine any subsequent pages.